



Energising Quality

REPLY TO BIDDER'S PRE-BID QUERIES-3 dated 21.12.2022

PROCUREMENT OF FIRE AND GAS SYSTEMS

FOR

NAMBOR – GOLAGHAT– NUMALIGARH AREA GAS PIPELINE PROJECT

Tender No : AGCL/BD/PMC-GHT/F&G/2020/158 dated 16/11/2022



(A GOVT. OF ASSAM UNDERTAKING)

Sr. No.	Tender Clause No. / Annexures	Page No	Clause No	Subject	Bidders Comments / Queries	VCS/AGCL Reply
1	REPLY TO BIDDER'S PRE-BID QUERIES/ Sr No.42/Page 06 of 08	6	-	SIL-2 Certification is required. Refer reply in sl.no.41 above Redundant CPU is required	Requirement of SIL2 Certification for FAP is not mentioned anywhere in the tender documents. Bidder request M/s AGCL/VCS to kindly confirm whether SIL2 certification is mandatory or not. If Yes, please confirm that SIL2 certification is required to be certified by Third party agencies like TUV/Exida/Eq. Also, as per the tender documents we understand that redundancy is only required for the communication and not at CPU level. The same can achieved by redundant communication port on proposed FACP and not by redundant controller. Bidder request M/s AGCL to kindly confirm whether bidder's understanding is correct.	1. SIL-2 Certification is Mandatory. Further, same is not required to be certified by Third party agencies. 2. Bidder's understanding is correct.
2	CORRIGENDUM #1	1.0	-	Bid Submission date and time: 15/12/2022 till 1430 Hrs. IST	Looking into the scope of work and time required for arranging the essential techno-commercial inputs/documents required for bid preparation. Bidder requests M/s. AGCL/VCS to kindly extend the bid submission due date by 3 weeks.	Bid Due Date has already been extended till 29.12.2022. Refer Corrigendum #2 dated 14.12.2022.

NOTE:
Bidder to submit signed & stamped copy of this Reply to Pre-Bid Queries-3 along with Un-Price Bid.